

## PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No. U1617321511490513

Dated: 16.12.2022

It is certified that an inspection team headed by Er. Saumilra(Name of Officers with designation) from Construction division U.P.J.N Kaushambi(Name of Department/ Office) inspected the T.R.S International School, Sarai Akil Ksb.(Name & Address of the school) on 16.12.2022 (date of inspection) and found that the T.R.S International School (Name of school) has safe drinking water facilities for the students and members of staff of the institution and is maintaining the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central/ State/ U.T. Govt.The above is valid for a period of 3 years

Signature with Seal: .....

Name Er. SaumilraDesignation Executive Engineer

Name &amp; Address of the Office / Department : .....

To

T.R.S International  
School, Sarai Akil Kaushambi

(Name &amp; Address of the Institution)

\* The filled up certificate should be either in Hindi or English. If it is issued in vernacular language, translated notarized version in English be uploaded along with the original vernacular certificate as a single pdf.

16.12.2022  
अधिसारी अभियन्ता  
खण्ड कार्यालय  
उ०प्र० जल निगम  
काशम्बी

## Health & Sanitation Certificate

No.

Date: 20/02/2023

I hereby declare that I have visited T.R.S. International School Sarai Akil, Kaushambi (UP). I find the school campus and the surrounding very conducive for the children and the staff. Each of the several school is sufficient for the maximum number of pupils. The school is kept neat and clean. The latrines and urinal are provided adequately and maintained well. There is sufficient amount of drinking water available. In all respect the sanitation is good.

So I certify that the sanitary conditions are satisfactory. Hence I recommend T.R.S. International School. For permission and recognition.

20/02/23  
प्रभ. चिकित्साधिकारी  
प्रा० स्वा० केन्द्र  
नेवादा, कौशांबी



# Jal Jeevan Mission

Har Ghar Jal



## District Level Water Analysis Laboratory, U.P Jal Nigam (Rural), Dist. Mirzapur

Office of Executive Engineer, Abhav Khand, U.P. Jal Nigam, Nakahara Road, Teliyaganj, Mirzapur. (Test Address only)

### Test report

Sample ID:

U1617321511490513

### User Information

Name:

TR S International school Sarai akil kaushambi

Mobile:

9918107499

Email:

principal trs is@gmail.com

Pin Code:

Full Address:

Village- Rasoolpur Tappa, Gram Panchayat- Rasoolpur Tappa, Block- Newada, District- Kaushambi, State- Uttar Pradesh

### Sample description

Source of Sample:

Schools

Village:

Rasoolpur Tappa

Gram Panchayat:

Rasoolpur Tappa

Block:

Newada

District:

Kaushambi

State:

Uttar Pradesh

Address:

Remarks:

Latitude:

Longitude:

Date & time of sample collection

12.04.2023 | 12:17:00 PM

Date & time of sample received in lab

12.04.2023 | 12:24:00 PM

Date & time of sample analysed

15.04.2023 | 11:25:00 AM

Date & time of report generation

15.04.2023 | 11:25:00 AM

### Test results

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
1	Calcium (as Ca)*	mg/l	75	200	76.076	
2	Chloride (as Cl)*	mg/l	250	1000	42.500	
3	Fluoride (as F)*	mg/l	1	1.5	0.638	
4	Free residual Chlorine	mg/l	0.2	1	0.000	

Sr. No.	Parameters tested	Unit of measurement	Requirement (acceptable limit) as per BIS 10500	Permissible limit (in absence of alternate source) as per BIS 10500	Test result value	Remarks
5	Iron (As Fe)*	mg/l	1	No Relaxation	0.440	
6	Magnesium (As Mg)*	mg/l	30	100	31.590	
7	Nitrate (as NO3)*	mg/l	45	No Relaxation	18.800	
8	pH*	NA	6.5-8.5	No Relaxation	7.490	
9	Sulphate (as SO4)*	mg/l	200	400	20.120	
10	TDS*	mg/l	500	2000	459.400	
11	Total Alkalinity (as Calcium Carbonate)*	mg/l	200	600	340.000	
12	Total coliform	CFU/ 100 ml	Shall not be detectable in any 100 ml sample	No Relaxation	0.000	
13	Total Hardness (As CaCO3)*	mg/l	200	600	320.000	
14	Turbidity*	NTU	1	5	1.530	

**Note:**

- 1)\*indicates parameters that are NABL accredited.
- 2)This test results related to the sample tested above
- 3)The report shall not to be reproduced in full without approval of authority
- 4)This is the end of the report

Authorised signatory

Avinash kumar Singh ( Test Lab Incharge)

**Jal Jeevan Mission aims at potable tap water supply to every home**

Let's join hands to ensure drinking water is potable. It helps in preventing water borne diseases and improve public health.

Designed & Developed by NIC. Copyright ©copy NJJM 2023

Print